


Idaho National Engineering and Environmental Laboratory

SCDAP-3D Analyses

D. L. Knudson

***2001 RELAP5 International Users Seminar
Sun Valley, Idaho, USA***

September 5-7, 2001



Outline


- *Introduction to recent SCDAP analyses*
- *Analyses of potential for in-vessel retention (IVR)*
 - *Modeling approach*
 - *Typical results*
- *Vessel lower head model improvements (in progress)*
- *Summary*

Wide Range of Analyses Completed

- *Station blackout analyses supporting*
 - *NRC severe accident management programs*
 - *Resolution of direct containment heating issue*
- *Fuel pin failure timing analyses (PWRs and BWRs)*
- *Analyses of potential for SGTR*
- *Electrosleeving analyses for SG life extension*
- *Vessel lower head analyses supporting*
 - *AP600 design certification relative to external reactor vessel cooling (ERVC)*
 - *Assessment of IVR potential*
 - *Addition of corium-to-vessel gap cooling (in progress)*


Minimal T-H Requirements for IVR Analyses

- Sink
- Injection source
- Simulation of external boundary conditions
(Radiation, spray cooling, external flooding, CRD supply)




Detailed IVR Model for Lower Head Thermal Response without CRD

- 744 finite elements with 800 nodes
- “Contact” elements at all corium/structural interfaces




Detailed IVR Model for Lower Head Thermal Response with CRD

- 753 finite elements with 812 nodes
- “Contact” elements at all corium/structural interfaces



“Contact” Heat Transfer Assumed to be Temperature Dependent



Solid interface (low conductance) if:

$$\frac{T_i + T_j}{2} < T_{solidus, structure}$$

Molten interface (high conductance) if:

$$\frac{T_i + T_j}{2} > T_{liquidus, structure}$$


Transition interface (intermediate conductance) if:

$$T_{solidus, structure} \leq \frac{T_i + T_j}{2} \leq T_{liquidus, structure}$$

Three Mechanisms Considered in IVR External Crucible Cooling (ECC)

- *ECC consists of heat transfer associated with
 - Radiation from crucible/CRD surfaces to surroundings
 - Spray cooling of external crucible/CRD surfaces
 - Nucleate boiling at submerged crucible/CRD locations*
- *Code modification made to allow specification of equivalent heat transfer coefficients using (user defined) control variables*
- *Control variables developed to implement heat transfer correlations at all affected nodes*

Notation Used to Develop IVR ECC Simulation



Radiation Heat Transfer Applied When Sprays are Off

- *Radiation heat transfer only applicable (at non-submerged nodes) when sprays “off”*
- *Equivalent radiation heat transfer coefficient given by*

$$h_{e-rad} = \frac{\varepsilon\sigma F(T_w^4 - T_\infty^4)}{(T_w - T_\infty)}$$

where $\varepsilon = 0.14$ for polished steel at 800 K

$\sigma =$ Stefan – Boltzmann constant

$F = 1.0$ (view factor to surroundings)

$T_w =$ crucible or CRD surface temperature

$T_\infty =$ surface temperature of surroundings

Spray Cooling Applied Above External Water Level

- Spray cooling only applicable for non-submerged nodes when sprays “on”
- Crucible spray cooling estimated using Breen and Westwater film boiling correlation

$$h_{e-spray-cru} = h_{e-rad} + h_{film}$$

where h_{e-rad} as previously defined

$$h_{film} = \left[0.59 + \frac{0.069(2\pi)}{D_{cru}} \left\{ \frac{\sigma_f}{g(\rho_f - \rho_g)} \right\}^{0.5} \right] \left[\left(\frac{\{g\sigma_f(\rho_f - \rho_g)\}^{0.5} \rho_g k_g^3}{2\pi\mu_g(T_w - T_\infty)} \right) \left(h_{fg} \left\{ 1.0 + 0.68 \left[\frac{c_{pg}(T_w - T_\infty)}{h_{fg}} \right] \right\} \right) \right]^{0.25}$$

D_{cru} = crucible outer diameter

σ_f = surface tension of saturated water

g = acceleration due to gravity

ρ_f = density of saturated water

ρ_g = density of saturated vapor

k_g = thermal conductivity of saturated vapor

μ_g = dynamic viscosity of saturated liquid

h_{fg} = heat of vaporization of saturated water

c_{pg} = specific heat of saturated vapor

Spray Cooling Applied Above External Water Level (cont)

- CRD spray cooling estimated using Bromley film boiling correlation

$$h_{e-spray-crd} = h_{e-rad} + h_{film}$$

$$\text{where } h_{film} = 0.62 \frac{D_{crd-o}}{2\pi} \left[\frac{g(\rho_f - \rho_g)}{\sigma_f} \right]^{0.5} \left[\frac{g(\rho_f - \rho_g) \rho_g k_g^3 [h_{fg} + 0.5 \{ \rho_{fg} (T_w - T_\infty) \}]}{D_{crd-o} \mu_g (T_w - T_\infty)} \right]^{0.25}$$

D_{crd-o} = CRD outer diameter

ρ_{fg} = difference in density between saturated liquid and saturated vapor

Spray Cooling Heat Transfer Limited by Flow

- *Crucible/CRD spray cooling heat transfer cannot exceed spray flow heat capacity*
- *Crucible/CRD equivalent heat transfer coefficient scaling required for consistency with spray flow heat capacity*

$$h'_{e-spray} = f_{spray} h_{e-spray}$$

$$\text{where } f_{spray} = \min \left[\frac{\dot{m}_{spray} c_p (T_{sat} - T_{spray}) + \dot{m}_{spray} h_{fg}}{\sum_{ext\ nodes} h_{e-spray} \Delta A (T_w - T_\infty)}, 1.0 \right]$$

\dot{m}_{spray} = spray mass flow rate

c_p = specific heat of spray flow

T_{sat} = saturation temperature for spray flow

T_{spray} = spray flow temperature

h_{fg} = heat of vaporization of spray flow

ΔA = surface area associated with external nodes

Boiling Heat Transfer Applied Below External Water Level

- Nucleate boiling assumed for all submerged nodes
- Boiling heat transfer assumes

$$h_{e\text{-boil-cru}} = \frac{0.7q_{CHF}}{\max(1.0, T_w - T_\infty)}$$


where

$$q_{CHF} = 49000 + 30200\theta - 888\theta^2 + 13.5\theta^3 - 0.0665\theta^4 \text{ (W/m}^2\text{)}$$

T_w = surface temperature (K)

T_∞ = pool temperature

θ = angle (in degrees) from vertical centerline to elevation of interest



- Boiling for all CRD surfaces based on $\theta = 0^\circ$

External Water Level Based on ECC Conditions

- External water level as function of spray cooling flow rates, spray cooling heat transfer, and boiling heat transfer

external water level = f(accumulated water volume)

accumulated water volume = spray accumulation - volume boiled

$$\text{spray accumulation} = \frac{\left[\dot{m}_{\text{spray}} c_p (T_{\text{sat}} - T_{\text{spray}}) + \dot{m}_{\text{spray}} h_{fg} - \sum^{\text{ext nodes}} h_{e\text{-spray}} \Delta A (T_w - T_{\infty}) \right] dt}{\rho_f h_{fg}}$$

$$\text{volume boiled} = \frac{\sum^{\text{ext nodes}} h_{e\text{-boil}} \Delta A (T_w - T_{\infty}) dt}{\rho_f h_{fg}}$$

where dt = SCDAP time step


IVR Results Dependent on Boundary Conditions

- *Wide range of boundary conditions considered*
- *Most significant conditions included*
 - *Corium temperature at time of relocation*
 - *Corium decay power density*
 - *Spray cooling flow rates*
 - *Corium/coolant interaction during relocation*


Structural Melting Sensitive to Initial Corium Temperature

Initial corium temperature 2250 K

Initial corium temperature 3000 K



Spray Scaling Requirement Increases with Initial Corium Temperature



Key Conclusions From IVR Analyses


- *Initial corium temperature significant relative to prediction of structural melting*
- *Spray flows considered were too small relative to external heat load*
- *CRD flows important for CRD integrity but ineffective relative to corium cooling*
- *In-vessel injection inadequate for replenishing/maintaining vessel water level*
- *Conclusions could change with addition of corium-to-vessel gap cooling*

Addition of Corium-to-Vessel Gap Cooling Significant SCDAP-3D Enhancement


- *Evidence suggests presence of corium-to-vessel gap*
 - *TMI-2 data*
 - *JAERI ALPHA experiments*
 - *KAERI LAVA tests*
- *Gap representation critical to accurate simulation of vessel lower head thermal response*
- *SCDAP-3D will contain high fidelity heat transfer model (not limited to simple CHF relationship used in some codes)*

Configuration Needed for Corium-to-Vessel Gap Cooling


- *Two volume gap allowing countercurrent cooling flow*
- *Crossflow connections incorporated in finite element mesh*
- *Heat transfer correlations*



Development of Complete Boiling Curve Anticipated



Addition of Corium/Vessel Gap Does Not Alter Existing “Contact” Modeling Approach



(a) Section AA without recommended modifications.

(b) Section AA with recommended modifications.

Summary

- *SCDAP-3D versatility demonstrated in completing wide variety of analyses*
- *Results have addressed regulatory and safety issues*
- *Recent IVR analyses provide insights into corium coolability (hence, reactor safety)*
- *SCDAP-3D modifications underway to add corium-to-vessel gap cooling capabilities*